

ADDENDUM No.3

No. 2024-109

911 Tower Remote Access and Surveillance

Date: May 13, 2024

To Whom It May Concern:

Here are responses to questions that have been asked in response to this RFP.

1. Will vendors be required to run conduit for all cabling ran at the tower locations? **Any exterior and underground cabling should be run in conduit.**
2. Will cameras be required to be placed inside of the tower buildings as well as outside of the buildings? Just need 360 perimeter coverage. No, **Just need 360 perimeter coverage.**
3. Is the 120 of the 150 mbps that is allocated for the camera(s) per tower location or for all of the locations combined? **120 is combined total of all**
4. Where is the connection for the Aviat system and what type of connection is it? **A single RJ-45 port will be configured at each site to connect to the Aviat system.**

RFP is due by 2:00 pm on May 16, 2024

Please reach out if you have any questions.



Brian Hanno
Lewis County Purchasing Director
7660 North State Street
Lowville, NY 13367

**Receipt of Addendum Acknowledgement
No. 2024-109
911 Tower Remote Access and Surveillance**

**ADDENDUM ACKNOWLEDGEMENT
ADDENDUM NO. _____**

**Please acknowledge the receipt of the above ADDENDUM issued by the County of Lewis,
by signature and recording the date of receipt below.
Bidder:**

Authorized Signatory: _____ Date:

****NOTE: This form must be included in your bid documents if any
Addendum is issued**